



**SJÖFARTSINSPEKTIONEN**

Fartygstekniska enheten

Handläggare, direkttelefon

Gabor Szemler, 011-19 12 93

STAT-X

Datum  
2006-12-01

Ert datum  
2006-11-23

Prime AS  
Hans Nordby  
Bamse Brakars vei 19  
N-3042 Drammen, Norway

1 (2)

Vår beteckning  
070202-06-17517

Er beteckning  
Registrering/ Godkännande

## **Acceptance of STAT-X Fixed Aerosol Fire Suppression System**

**This is to certify that the design of:**

Stat-X Fire Extinguishing Aerosol System can be installed in cargo vessel below 500BT/grt and fishing vessel with a length up to 24 meters.

### **Product description:**

A small boat Machinery Space STAT-X fixed aerosol fire suppression system.

### **Aerosol generators:**

Stat-X units; as specified in approval issued by Maritime and Coastguard Agency (MCA) UK, File Reference MS 47/ 11/ 1042

### **Manufacturer:**

Fireway LLC

11503 K-Tel Drive, Minnetonka, MN 55343, USA

Tel. (+1) 952 935 9747

Fax: (+1) 952 935 9757





Datum  
2006-12-01

Vår beteckning  
070202-06-17517

**Acceptance conditions:**

This acceptance is based on certificate issued by the Maritime and Coastguard Agency (MCA) UK, File Reference MS 47/ 11/ 1042

The STAT-X fixed aerosol system is considered suitable for installation in normally unoccupied spaces containing fuel having a flash point of less than 43 degrees C (closed cup test), of vessels of less than 24 meters load line length, where the space to be protected does not exceed deck height of 4 meters, or an area of 64m<sup>2</sup>, provided that the condition attached to the schedule in the MCA certificate are fulfilled and the product remains satisfactory in service.

Regardless of the Swedish Maritime Safety Inspectorate's acceptance conditions, the liability for the product rests with the supplier.

Issued in Norrköping 2006-12-01

Best Regards

**Gabor Szemler**

**Marine Engineer**

**Swedish Maritime Safety Inspectorate**

**Ship Technical Division**