



October 30, 2009

Mr. Marc Gross
Fireaway LLC
11503 K-Tel Drive
Minnetonka, MN 55343 USA

Our Reference: FILE EX15004

Subject: Stat-X Aerosol Generating Extinguishing System Units, Nominal
30, 60, 100, 250, 500, 1000, 1500 and 2500 Gram Sizes

Dear Mr. Gross:

This is in response to your request of October 30, 2009, regarding the Listing and Certification of the subject extinguishing system units, by Underwriters Laboratories Inc.

This will confirm that UL Lists and certifies the Stat-X Models 30 E, 60 E, 100 E, 250 E, 500 E, 1000 E, 1500 E and 2500 E in the 30, 60, 100, 250, 500, 1000, 1500 and 2500 gram nominal capacities, respectively. The units have been tested in accordance with UL Subject 2775, the Outlines of Investigation for Aerosol Generating Extinguishing System Units.

It is important to note that the only indication of UL Listing and Certification of the aerosol generating extinguishing system units is the UL Mark on the product.

Should you have any questions or comments regarding this Listing, please feel free to contact us.

Written by:

KEVIN HOLLY
Senior Project Engineer
Fire Protection Division
Department 3019CFPD
847-664-3494
Kevin.Hollyjr@us.ul.com