

UL-EU CERTIFICATE

Certificate No.
UL-EU-01339-EN

Issue date
2025-03-25

Issue No.
1

Re-Issue date
-

Expiry date
2035-03-24

Certificate Holder:
FIREAWAY INC

Address:
5852 BAKER RD
MINNETONKA,
MN, 55345-5903, USA

Product:
Stat-X E-Series Aerosol-generating Extinguishing System Units

Models: 30E, 60E, 100E, 250E, 500E, 1000E, 1500E and 2500E

Places of production:

Fireaway Inc.
5852 Baker Rd.
Minnetonka, MN 55345-5903
USA

Fireaway Inc.
1006 2nd St, Area J
Camp Minden
Minden, LA 71015
USA

Standard:
EN 15276-1:2019

Authorised Signatory:



Richard Bristow
Issued by UL International (UK) Ltd



4705

This is to certify that representative samples of the Certified Product listed above have been investigated by Underwriters Laboratories to the Standard(s) indicated on this Certificate, in accordance with the UL Global Services Agreement and the UL-EU Mark Service Terms and Conditions ("Agreement"). The Certificate Holder is entitled to use the UL-EU Mark for the Certified Product listed on the certificate and manufactured at the production site(s) listed, in accordance with the terms of the Agreement. Only those products bearing the UL-EU Mark for Europe should be considered as being covered by UL's UL-EU Mark Service. This Certificate shall remain valid through the Expiration date, unless a Standard identified on this Certificate is amended or withdrawn prior to that date or there is a non-compliance with the Agreement.



Appendix UL-EU CERTIFICATE UL-EU-01339-EN

Stat-X, E-Series (electric activation), aerosol-generating extinguishing system units for protection of surface-type Class A, B and C fires that occur in an enclosed volume over a temperature range of -40 to 54°C.

Description	Part No.
Condensed Aerosol Generator, Model 30E	15100
Condensed Aerosol Generator, Model 60E	15110
Condensed Aerosol Generator, Model 100E	15120
Condensed Aerosol Generator, Model 250E	15130
Condensed Aerosol Generator, Model 500E	15140
Condensed Aerosol Generator, Model 1000E	15150
Condensed Aerosol Generator, Model 1500E	15160
Condensed Aerosol Generator, Model 2500E	15170
Mounting bracket for Models 30E and 60E	18001
Mounting bracket for Model 100E	18006
Mounting bracket for Models 250E and 500E	18011
Mounting bracket, for Models 1000E, 1500E, and 2500E	18016
Design, Installation, Operation, and Maintenance Manual, Dated March 2025, Rev. 1.7.1	19000
Owner's Manual, Dated December 2024, Rev. 1.5.0	19001

Appendix UL-EU CERTIFICATE UL-EU-01339-EN

Construction Product:

1. Electrically activated aerosol-generating extinguishing system units

Intended Use:

1. Fire Suppression

The product is certified on the basis of:

- i) EX29524-D01-European Directive-Original
- ii) Inspection and surveillance of factory production control by UL
- iii) Being designed, installed, operated, inspected, tested, and maintained in accordance with the following:
 - o National Laws and regulations.
 - o EN 15276-2:2019, Fixed firefighting systems – Condensed aerosol extinguishing systems – Part 2: Design, installation and maintenance, issued April 2019
 - o Manufacturer's design, installation, operation and maintenance instruction manual.
 - o Authorities Having Jurisdiction (AHJ) requirements.

For information regarding safeguards, see EN 15276-2.



Appendix UL-EU CERTIFICATE UL-EU-01339-EN

Standard: EN 15276-1:2019

Clause	Essential Characteristics	Performance
5.16 and 5.1	Design, installation, operation and maintenance instruction manual	Pass
6	Nameplate marking	Pass
7.4 and 5.2, Annex A.6.1	Wood crib test - Extinguishing density tests - Extinguishing density determination	Pass
7.4 and 5.2, Annex A.6.2	n-Heptane pan test - Extinguishing density tests - Extinguishing density determination	Pass
7.4 and 5.2, Annex A.6.3	Polymeric sheet fire test - Extinguishing density tests - Extinguishing density determination	Pass
7.4 and 5.2, Annex A.6.4	Class A compatible wood crib test - Extinguishing density tests - Extinguishing density determination	Pass
7.4 and 5.2, Annex A.6.5	EN 2, Class C, fires gas - Extinguishing density tests - Extinguishing density determination	Pass
7.4 and 5.2, Annex A.7	Hold Time Test of the determination of the maximum leakage area - Extinguishing density determination	Pass
7.5 and 5.3, Annex A.5.1, A.5.2	Agent distribution coverage determination	Pass
7.6.1, 7.6.2 and 5.1, 5.4, 5.5, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Temperature & humidity operation range tests	Pass
7.6.3 and 5.1, 5.4, 5.5, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Low-temperature test	Pass
7.7 and 4.5, 5.1, 5.4, 5.5, 5.6, 5.7, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Accelerated ageing test	Pass
7.8 and 4.5, 5.1, 5.4, 5.5, 5.8, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Salt spray corrosion test	Pass
7.9	Stress corrosion test	Not applicable
7.10 and 5.1, 5.4, 5.9, 5.15, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Vibration test	Pass
7.11 and 5.1, 5.4, 5.10, 5.15, 7.1, 7.2, 7.3, 7.14.1, 7.14.3, 7.14.6	Drop test	Pass
7.13 and 4.4.1, 4.4.2, 5.12.1, 5.12.2	Activation performance test	Pass
7.14 and 5.1, 5.4, 5.11, 5.13, 7.1, 7.2, 7.3, 7.12	Function test	Pass
7.15 and 5.14, 7.14.1, 7.14.3	Fire exposure test	Pass

Appendix UL-EU CERTIFICATE UL-EU-01339-EN

The UL-EU Mark, as displayed below, shall appear on certified products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested.



The minimum height of the registered trademark symbol ® shall be 1 mm. When the overall diameter of the UL-EU Mark is less than 9.5 mm, the trademark symbol may be omitted if it is not legible to the naked eye.

The UL-EU Mark may appear on a label, nameplate, or may be cast, stamped or molded into the product. When appearing on a label or nameplate, the Manufacturer's name or trademark along with a model number are also required on that same label or nameplate. If cast, stamped or molded, the Manufacturer's name or trademark and model number shall also appear elsewhere on the product.

All content shall be in accordance with the details provided on this UL-EU Certificate.

PROCUREMENT

The Production site may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized suppliers can be found on UL's online directory at www.ul.com.



Solutions

Form-ULID-006104 V8.0